



नवी मुंबई
महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/80/2024-2025

Date : 17/09/2025

Date of sample received. : 17/09/2025 Date of sample testing : 17/09/2025 to 19/09/2025

Customer's Name and Location : Orchid International School

Plot No. 59, Sector - 14

Koperkhairne, Navi Mumbai

TEST REPORT

Sr. No.	Testing Parameter	Test Result	Test Standards (IS 10500 : 2012)
01	pH	7.9	6.5 - 8.5
02	Turbidity	0.0	Max. 5.0 N.T.U.
03	Residual Chlorine	3.0	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 80

Date : 19/09/2025

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Assitant Lab Chemist

Lab Chemist

Lab Incharge

Orchids The International School

Environment Laboratory
Navi Mumbai Municipal Corporation

Orchids The International School

Sriyatsa Sai Krishna
Manager